

KEYED PLAN NOTES:

- ① REMOVE SUPPLY DUCT FROM AIR TERMINAL TO POINTS SHOWN; IF INDICATED, REMOVE ASSOCIATED DIFFUSERS.
- ② REMOVE EXISTING AIR DEVICE, VAV TERMINAL UNIT, HEAT EXCHANGER AND ASSOCIATED DUCTWORK AND HW PIPING AS INDICATED. RETURN TERMINAL UNIT AND HEAT EXCHANGER TO OWNER'S STOCK. RELOCATED ASSOCIATED THERMOSTAT TO LOCATION SHOWN ON RENO PLAN & CONNECT TO NEW TERMINAL 11-TU-1-4.
- ③ CUT EXIST. DUCT & REMOVE DASHED PORTION & ANY ASSOCIATED DIFFUSERS; MODIFY DUCT PER RENO PLAN.
- 4 REMOVE BRANCH DUCT & ANY ASSOCIATED DIFFUSERS; PATCH TRUNK DUCT AIR TIGHT & REPAIR INSULATION; ENSURE VAPOR BARRIER.
- 5 REMOVE DUCTWORK TO POINTS SHOWN; PREPARE EXIST. DUCT FOR MODIFICATION PER RENO PLAN.
- RELOCATE EXIST. THERMOSTAT TO NEW POSITION PER RENO PLAN.
- 7 REMOVE GRILLE AT BOTTOM OF DUCT, MODIFY DUCT PER RENO PLAN.
- ® RE: RENO PLAN FOR MODIFICATIONS TO THESE AIR TERMINALS & HEAT EXCHANGERS.

"ISSUED FOR BIDS"-FULLY SPRINKLERED

08/02/10 09/03/10 SCHEMATIC DESIGN SUBMISSION DESIGN DEVELOPMENT SUBMISSION CONSTRUCTION DOCUMENT SUBMISSION 11/22/10 ISSUE FOR BIDS 12/19/11 Burns, DeLatte & McCoy, Inc.
Texas Registered Engineering Firm
F-685

one eighth inch = one fc

VA FORM 08-6231

WILSON ARCHITECTURAL GROUP

MEP ENGINEERS STRUCTURAL ENGINEERS FIRE PROTECTION ENGINEERS CIVIL ENGINEERS

BURNS DELATTE AND McCOY, INC. PINNACLE STRUCTURAL PROTECTION DEVELOPMENT INC. BREWER AND ESCALANTE

Project Title Project Number 674A4-CSI-516 MECHANICAL LEVEL 2 BUILDING 11 ADDITION AND DEMOLITION PLAN INTERIOR RENOVATIONS Building Number SCALE: 1/8" = 1' - 0" Approved: Project Director Location Drawing Number WACO, TEXAS MH105 Checked PHJ Dwg. of

Office of Construction and Facilities Management

Department of Veterans Affairs